

Planning Department
Building Control Unit
P.O. Box 31206
Grand Cayman KY1-1205
CAYMAN ISLANDS



Phone: (345) 769-PLAN (7526)
Fax: (345) 769-2228
Email: Building.Control@gov.ky

PRODUCT APPROVAL

March 19, 2009

Sam Small
Small Engineering
PO Box 309 GT
Grand Cayman KY1-1602
Cayman Island
345-947-9330
345-947-7385 Fax
thesmallgroup@candw.ky

RE: **Quad-lock Polystyrene forms for Concrete Walls**

The Standard Building Code incorporates, by reference, nationally recognized consensus standards for use in judging the performance of materials and systems. This provides for the equal treatment of both innovative and traditional materials and systems, which allows for introduction of new materials into the construction process and assures a high level of consumer protection.

Quad-lock systems shall follow the guidelines as established by ICC ES Legacy Report ER-5188 meet this standard. It is important to pay particular attention to section 2.10 that outlines the requirement for Special Inspection and item #3 of that section that requires the installation to be done by approved installers.

The Building Control Unit (BCU) will approve such material as long as it follows the requirements as outlined in ER-5188. In lieu of the special inspection requirement a report/letter of acceptance by the engineer of record will suffice. However we still require that the installer be approved by Quad-lock.

Respectfully,

A handwritten signature in black ink that reads 'Lee Bodine'. The signature is written in a cursive style.

Lee Bodine CBO
Building Control Unit
Assistant Building Control Officer - Operations
Ph 345-769-7526 x1517 BCU Fax 345-769-2228
leroy.bodine@gov.KY