

Planning Department  
Building Control Unit  
P.O. Box 31206  
Grand Cayman KY1-1205  
CAYMAN ISLANDS



Phone: (345) 769-PLAN (7526)  
Fax: (345) 769-2228  
Email: [Building.Control@gov.ky](mailto:Building.Control@gov.ky)

## PRODUCT APPROVAL

March 19, 2009

Sam Small  
Small Engineering  
PO Box 309 GT  
Grand Cayman KY1-1602  
Cayman Island  
345-947-9330  
345-947-7385 Fax  
[thesmallgroup@candw.ky](mailto:thesmallgroup@candw.ky)

RE: **Quad-lock Polystyrene forms for Concrete Walls**

The Standard Building Code incorporates, by reference, nationally recognized consensus standards for use in judging the performance of materials and systems. This provides for the equal treatment of both innovative and traditional materials and systems, which allows for introduction of new materials into the construction process and assures a high level of consumer protection.

Quad-lock systems shall follow the guidelines as established by ICC ES Legacy Report ER-5188 meet this standard. It is important to pay particular attention to section 2.10 that outlines the requirement for Special Inspection and item #3 of that section that requires the installation to be done by approved installers.

The Building Control Unit (BCU) will approve such material as long as it follows the requirements as outlined in ER-5188. In lieu of the special inspection requirement a report/letter of acceptance by the engineer of record will suffice. However we still require that the installer be approved by Quad-lock.

Respectfully,

**Lee Bodine CBO**  
Building Control Unit  
Assistant Building Control Officer - Operations  
Ph 345-769-7526 x1517 BCU Fax 345-769-2228  
[leroy.bodine@gov.KY](mailto:leroy.bodine@gov.KY)